BAKHTI Software Ltd


Civil engineering software development

Website: https://www.bakhtisoftware.com

Email: bakhti@bakhtisoftware.com/ support@bakhtisoftware.com

Project:

Client:
Location:
Date: 2026-09-26



PROCTOR COMPACTION TEST

NF P 94-093

Test	Proctor N°=1
Type	Modified
Mould	CBR
Rammer mass (kg)	4.540
Blows height (cm)	45.70
Number of layers	5
Number of blows / layer	55
Large particles	0 %

γ_{OPM} = 19,76 kN/m³
W_{OPM} = 8,90 %
$\gamma_{OPM\ (Corrected)}$ = 19,76 kN/m³
$W_{OPM\ (Corrected)}$ = 8,90 %

Software: CiviLab 2027